



# **SNS COLLEGE OF TECHNOLOGY**

**(An Autonomous Institution)**



**COIMBATORE-35**

**Accredited by NBA-AICTE and Accredited by NAAC – UGC with A+ Grade**

**Approved by AICTE, New Delhi & Affiliated to Anna University, Chennai**

**DEPARTMENT OF ELECTRICAL AND ELECTRONICS ENGINEERING**

**COURSE NAME: 19EEB201 DC MACHINES AND TRANSFORMERS**

**II YEAR / III SEMESTER**

**Unit 1 – DC Generator**

**Topic 4: Types of DC generator**





# What We'll Discuss


## TOPIC OUTLINE



A Case  
Classification of DC Generator  
Types of Excitation  
Assessment





# A CASE



- Identify the types of Generating stations
- Think whether the same types of generator can be used in all these places?




# Classification - DC Generator





# Permanent Magnet DC Generator




**PERMANENT MAGNET DC GENERATOR**

- When the flux in the magnetic circuit is created through the use of permanent magnets, then it is known as a Permanent magnet DC generator.
- It consists of an armature and one or several permanent magnets situated around the armature.
- They are normally used in small applications – like dynamos in motorcycles.



# Separately Excited DC Generator



These are the generators whose field magnets are energized by some external DC source, such as a battery.

- $I_a$  = Armature current
- $I_L$  = Load current
- $V$  = Terminal voltage
- $E_g$  = Generated EMF (Electromagnetic Force)

Voltage drop in the armature =  $I_a \times R_a$

- $E = V_t + I_a R_a + BCD$



# Self Excited DC Generator



- Field magnets are energized by the current supplied by themselves.
- In these type of machines, field coils are internally connected with the armature.
- Due to residual magnetism, some flux is always present in the poles.
- When the armature is rotated, some EMF is induced. Hence some induced current is produced.
- This small current flows through the field coil as well as the load and thereby strengthening the pole flux.
- As the pole flux strengthened, it will produce more armature EMF, which cause the further increase of current through the field.
- This increased field current further raises armature EMF, and this cumulative phenomenon continues until the excitation reaches the rated value.

According to the position of the field coils, self-excited DC generators may be classified as:


- 1. Series Wound Generators**
- 2. Shunt Wound Generators**
- 3. Compound Wound Generators**



# Series Wound Generator



- In these type of generators, the field windings are connected in series with armature conductors



Here:

$R_{sc}$  = Series winding resistance

$I_{sc}$  = Current flowing through the series field

$R_a$  = Armature resistance

$I_a$  = Armature current

$I_L$  = Load current

$V$  = Terminal voltage

$E_g$  = Generated EMF








# Shunt Wound Generator



- In these type of generators, the field windings are connected in parallel with armature conductors



Here:

$R_{sh}$  = Shunt winding resistance

$I_{sh}$  = Current flowing through the shunt field

$R_a$  = Armature resistance

$I_a$  = Armature current

$I_L$  = Load current

$V$  = Terminal voltage

$E_g$  = Generated EMF







# Compound Wound Generator



- Compound wound generators have both series field winding and shunt field winding. One winding is placed in series with the armature, and the other is placed in parallel with the armature.






# Compound Wound Generator




In a compound wound generator, the shunt field is stronger than the series field. When the series field assists the shunt field, generator is said to be **commutatively compound wound**.

On the other hand, if the series field opposes the shunt field, the generator is said to be **differentially compound wound**.





# Recall the types of DC Generator





# THANK YOU